



रा. ल. उ. नि. तकनिकी सेवा केन्द्र
(भारत सरकार का उद्यम)

आजी प्रयोगिक केंद्र
राजकोट - ३६० ००३.
दूरभाष : ३८७३९५-९७-९८
फैक्स : ०२८१ - ३८७७२९

M/s. A1 Electricals
NSIC TECHNICAL SERVICES CENTRE
The National Small Industries Corporation Ltd.
(A Government of India Enterprise)

Aji Industrial area,
Bhavnagar Road,
Rajkot - 360 003.
Phone : 387395-97-98
Fax : 0281 - 387729

Torque test report

438

Name of Party : M/s. A1 Electricals,
Rajkot
Enquiry No. & Date : 102 Dt. 11-05-07
Testing Date : 18/05/07

Sample Details: Brass Cable Gland
Details of Instrument: -
Quantity: -
Sr. No. -
Other Details: -



Torque Test: The minimum acceptable torque test on cable glands were done as per BS6121

Gland Size	Min acceptable Torque(Nm)	Remarks
20S (ABW20S)	65	Pass
20 (ABW20)	65	Pass
25 (ABW25)	95	Pass
32 (ABW32)	110	Pass
40 (ABW40)	130	Pass
50 (ABW50)	165	Pass
63 (ABW63)	195	Pass

Tested By :

Dy. Manager (Testing)

[Signature]
Manager (Testing)

Note : 1. No part of this Report may Reported except in Full without the prior written permission of the head of the Department.
2. The Results pertain to specify sample only.